
FIG. 62 JUNIOR TOP BEAM CLAMP









Address:

Approved [

Date:

Material: Malleable iron with hardened steel set screw. 304 (62SS) and 316

(62SX) stainless steel.

Finish: Plain, electro-galvanized, stainless steel 304 and 316.

Service: Designed to attach hanger rod to the top flange of a beam or bar

joist where flange thickness does not exceed 5/8

of an inch.

Approvals: U.L. - U.L.C. listed $^{3}/_{8}$ and $^{1}/_{2}$ ($^{1}/_{2}$ for 4" IPS max). FM approved for

³/₈ only. Complies with Federal Specification A-A-1192 A (Type# 19) and Manufacturers' Standardization Society MSS SP-58 and

SP-69 (Type# 19).

Ordering: Specify rod size, material, figure number and finish.

Notes: See MSS SP-69 for proper set screw recommendations.

Stainless steel beam clamps are recommended for corrosive

environments. Order 62D for domestic.

ROD SIZE A	SET SCREW	В	С	D	Е	F	MAX PIPE SIZE	MAX REC LOAD (lbs)	WEIGHT EACH (lbs)
3/8-16	³ /8-16	1 ⁵ /16	1 ¹ / ₂	1/2	1	7/8	4	350	0.320
1/2-13		1 ⁵ /16	1 1/2	1/2	1	7/8	4	470	0.320
⁵ /8-11		1 ³ / ₄	1 ³ / ₄	5/8	1 ³ /8	1 ¹ /8	5	550	0.580
3/4-10		1 ⁷ /8	1 ⁷ /8	5/8	1 ³ /8	1 ³ /8	6	700	0.820
⁷ /8-9	1/2-13	2 3/8	1 ⁷ /8	5/8	1 ³ /8	1 ³ /8	8	1000	0.795

Project:			INIAL // N	lotes:	JIKIAL ///
IMPRICABLE	Project In	TDIAL	Approval Stamp		

Not Approved

Contractor:

Engineer:

Approved as Noted \square